



CB TEST CERTIFICATE

Ref. Certificate No.

NL-11541

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Terminal blocks for copper conductors		
Applicant:	Raad manufacturing Co.	20 th Ave. Azadegan Rd. Isfahan	Iran
Manufacturer:	Raad manufacturing Co	20 th Ave. Azadegan Rd. Isfahan	Iran
Factory:	Raad manufacturing Co	20 th Ave. Azadegan Rd. Isfahan	Iran
Rating and principal characteristics:	RDT4 : 1,5 mm ² , 17,5 A, 500 V RDT4-TS : 1,5 mm ² , 17,5 A, 500 V RSTT6 : 6 mm ² , 41 A, 400 V		
Trade mark (if any):	Raad		
Model/Type reference:	RDTP4, RDT4-TS and RSTT6		
Additional information:			
Sample of product tested to be in conformity with IEC:	60947-7-1(ed.2)		
Test Report Ref. No:	2096555.50 and 2096555.51		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.H.M. Versteegen

Date of issue: 2006-11-27

