



CB TEST CERTIFICATE

Ref. Certificate No.

NL-11016

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Terminal blocks for copper conductors		
Applicant:	Raad manufacturing Co.	20 th Ave. Azadegan Rd. Isfahan	Iran
Manufacturer:	Raad manufacturing Co	20 th Ave. Azadegan Rd. Isfahan	Iran
Factory:	Raad manufacturing Co	20 th Ave. Azadegan Rd. Isfahan	Iran

Rating and principal characteristics:

DRTP 4 : 4 mm², 32 A, 500 V
RTP 95 : 95 mm², 232 A, 1000 V
RET 2,5 : 2,5 mm²
RET 4 : 4 mm²
RET 6 : 6 mm²
RET 10 : 10 mm²
RET 16 : 16 mm²
RET 35 : 35 mm²

Trade mark (if any): Raad

Model/Type reference: DRTP 4, RTP 95, RET 2,5, RET 4, RET 6, RET 10, RET 16, RET 35

Additional information:

Sample of product tested to be in conformity with IEC: 60947-7-1(ed.2)
60947-7-2(ed.2)

Test Report Ref. No: 2093439.50 up to and including 2093439.57

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H. H. M. Versteegen

Date of issue: 2006-08-22

